

PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. -05/2025-26

Dated: 27.05.2025

It is certified that an inspection team headed by **Raghvendra Kumar Mishra**, Lab In charge, District Level Water Analysis Laboratory, Deoria (Name of officers with designation) from **UP Jal Nigam (Rural) Deoria** (Name of Department/office) Inspected the **UP PUBLIC SCHOOL, NARAULI BHIKHAM-TENUA, KHUKHUNDOO, DEORIA** (Name & Address of the school) on **26.05.2025** (Date of inspection) and on the basis of water test report (Attached) Report no: **WTD/004/MAY(25-26)** dated **26.05.2025** of District Level Water Analysis Laboratory, Deoria (PHED-lab) certified that the **UP PUBLIC SCHOOL, NARAULI BHIKHAM-TENUA, KHUKHUNDOO, DEORIA** (Name of school) has safe drinking water facilities for the students and staffs of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central /state /U.T.Govt.

This certificate is valid till **01 Year** from date of issue. In case, if there is any change in Drinking Source /gone under maintenance before Expiry of certificate, then this certificate will be no more valid. So to avoid this problem School is advice to send Drinking Water Sample on Regular Interval to District Level Water Analysis Laboratory, Deoria.

Signature with Seal.....

Name **E.Y. SUNEEL KUMAR** Division OfficeDesignation **ASSISTANT ENGINEER** Deoria

Name & Address of the office/Department

**Uttar Pradesh Jal Nigam Rural, Bhujauli Colony,
Deoria**

Manager
U.P. PUBLIC SCHOOL
Bhujauli Bikhham, Tenua, Khukhundoo
Deoria

To

MANAGER,
UP PUBLIC SCHOOL,
NARAULI BHIKHAM-TENUA,
KHUKHUNDOO, DEORIA (Name & Address of the institution)

Principal
U.P. PUBLIC SCHOOL
Narauli Shikham, Tenua, Khukhundoo
Deoria

Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies.



District Level Water Analysis Laboratory
Uttar Pradesh Jal Nigam (Rural), Deoria
Add.- M2, 1st Construction Division, Bhujauli Colony, Deoria 274001

Test Report

Report No	WTD/004/MAY(25-26)	Date	26.05.2025	Page No	01/01
-----------	--------------------	------	------------	---------	-------

Customer Details

Office Name and Address	UP PUBLIC SCHOOL, NARAU LI BHIKHAM-TENUA, KHUKHUNDOO, DEORIA
Ref Letter No & Date	Letter No- 670, DATED 23.05.2025

Basic details of sample

District	DEORIA	Block	BHALUANI
Gram Panchayat	NARAU LI BHIKHAM	Village	TENUA
Habitation	TENUA	Location	TENUA, SCHOOL CAMPUS
Water Source	BOREWELL	WQMIS Id	----
Quantity of Sample	1000 ml	Date of S.C.	23.05.2025
Receiving Date	23.05.2025	S. Collector	SCHOOL ADMINISTRATION
Sample Depositor	SCHOOL ADMINISTRATION		
Analysis Start Date	23.05.2025	Analysis Completion Date	26.05.2025

Temperature- 25±3°C

Relative Humidity- 50±15%

Technical Data of Analysis


S. No.	Analysed Parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS 10500:2012		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8)): 2023
2	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5)): 2018
3	pH	7.70	6.5	8.5	IS 3025(Part 11): 2022
4	Turbidity (NTU)	1.48	1.0	5.0	IS 3025(Part 10): 2022
5	TDS (mg/l)	262	500	2000	IS 3025(Part 16): 2023
6	Total Alkalinity (mg/l)	180	200	600	IS 3025(Part 23): 2023
7	Total Hardness (mg/l)	184	200	600	IS 3025(Part 21): 2019
8	Calcium (mg/l)	30.4	75	200	IS 3025(Part 40): 2024
9	Magnesium (mg/l)	26.24	30	100	IS 3025(Part 46): 2023
10	Chloride (mg/l)	20.9	250	1000	IS 3025(Part 32): 2019
11	Fluoride (mg/l)	0.24	1.0	1.5	APHA 24 TH Edition 4500-F Method-C (Electrode Method)
12	Nitrate (mg/l)	1.29	45	No relaxation	APHA 24 TH Edition -NO ₃ Method D(UV screening Method)
13	Sulphate (mg/l)	2.97	200	400	APHA 24 TH Edition 4500-SO ₄ Method E(Turbidititrimetric Method)
14	Iron (mg/l)	BDL (0.07<0.1)	1.0	No relaxation	APHA 24 TH Edition - 3500-Fe Method B(Phenanthroline Method)

#BDL- Below Detection Limit, NA- Not Applicable. ** Parameter(s) above permissible limit are in bold digits.

- Note
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
 4. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of test reports unless otherwise specified.

Savitri
Tested By

Raghvendra K Mishra
RAGHVENDRA K MISHRA(T.M.)
Reviewed By



Raghvendra K Mishra
RAGHVENDRA K MISHRA(T.M.)
Authorized Signatory

Email id- labdeoria@gmail.com

Contact No-7905141804

*****End of test report*****

(Signature)
Manager
U.P. Jal Nigam (Rural),
Narauli Bhikham, Tenua, Khukhundo
Deoria

(Signature)
Principal
U.P. PUBLIC SCHOOL
Narauli Bhikham, Tenua, Khukhundo
Deoria



DISTRICT LEVEL WATER ANALYSIS LABORATORY

UTTAR PRADESH JAL NIGAM(R), BHUJAULI COLONY, DEORIA 274001

BACTERIOLOGICAL SAMPLE TEST REPORT

Rept. No WTD/004/MAY(25-26) Date: 26.05.2025 Page No 1/1

Customer Details

Office Name and Address UP PUBLIC SCHOOL, TENUA, NARAU LI BHIKHAM, KHUKHUNDOO, DEORIA
Ref Letter No & Date --

Basic details of sample

District	DEORIA	Block	BHALUANI
Gram Panchayat	NARAU LI BHIKHAM	Village	TENUA
Habitation	TENUA	Location	SCHOOL CAMPUS
Water Source	BOREWELL	Sample Code	--
Quantity of Sample	500ML	Date of S.C.	23.05.2025
Receiving Date	23.05.2025	S. Collector	UP PUBLIC SCHOOL
Sample Depositor	UP PUBLIC SCHOOL		
Analysis Start Date	23.05.2025	Analysis Completion Date	26.05.2025

Technical Data of Analysis

Sr. No	Analyzed parameters (Unit of Measurement)	Observed Value	Unit	Specified Values as per BIS		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	pH	7.70	--	6.5-8.5	No relaxation	IS 3025 (Part 11):2022
2	Residual Chlorine	NA	mg/L	0.2	1.0	IS 3025 (PART 26) : 2022
3	Total Coli form	Absent	CFU	No relaxation	--	APHA 24 th Edition :2023
4	E .Coli	Absent	CFU	No relaxation	--	APHA 24 th Edition :2023

Result : SAFE

Remark: SATISFACTORY

- Note 1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 7 days (in case of non perishable items only) from the date of issue of tests reports unless.


SANJEEV KUMAR

Prepared By

Laboratory Contact details: Email-labdeoria@gmail.com






SONAL MISHRA

TESTED BY

Contact - +91 7905141804

End of the Report


Manager
U.P. PUBLIC SCHOOL
Narauli Bhikham, Tenua, Khukhundo, Deoria


Principal
U.P. PUBLIC SCHOOL
Narauli Bhikham, Tenua, Khukhundo, Deoria